



Government Of West Bengal
Office Of The Divisional Fire Officer, South 24 Parganas
West Bengal Fire & Emergency Services
6, Diamond Harbour Road, Silpara, Kol-700008

Memo no.: IND/WB/FES/20192020/75498

Date: 13-07-2020

From:

The Divisional Fire Officer, South 24 Parganas
West Bengal Fire & Emergency Services

To: The Calcutta Barisha Good Shepherd Mission

2A, Kenaram Ganguly Road, Barisha, Kokata-700008

Sub: Fire Safety Certificate for an existing construction of G+3 storied building under group Educational at the premises No:-2A, Kenaram Ganguly Road, Barisha, Thakurpukur, Dist.-South 24 Parganas, Kolkata-700008.

This is in reference to your application no. 0125189201200352 dated 13-07-2020 regarding the Fire Safety Certificate for an existing construction of G+3 storied building under group Educational at the premises No:-2A, Kenaram Ganguly Road, Barisha, Thakurpukur, Dist.-South 24 Parganas, Kolkata-700008.

The performance of the Fire Fighting System as incorporated in the buildings were tested at random and found satisfactorily working condition. In view of the above this office is releasing the Fire Safety Certificate for occupancy of the aforesaid building.

Recommendation:

1. Driveway must be free from any type of obstruction for easy movement of Fire Appliances. No parking will be allowed on the driveway. The interior finish decoration of the building shall be with low flame spread material confirming I.S. specification.
2. To eliminate risk of Fire hazards, good housekeeping both for inside and outside of the Existing building shall be strictly maintained.
3. Electrical wiring of the whole building shall have to be carefully checked for wear and tear in them, particularly lines above false ceiling and ducts.
4. The notice of Fire fighting and evacuation from the building shall be prepared and displayed at all vulnerable place of the building.
5. The employees and security staff shall be conversant with installed Fire fighting equipment's of the building and to operate in the event of Fire and testing.

The authenticity of this document can be verified by accessing the URL: edistrict.wb.gov.in and then clicking on the 'Verification of Digitally Signed Document' link and keying in the Unique Number : 0125189201200352.

Page : 1

6. Mock Fire practice and evacuation drill shall be performed periodically with participants of all the occupants of the building.
7. Transformer and switch gear room shall be protected with automatic CO2 or D.C.P Fire extinguisher conforming I.S. specification.
8. First aid Fire fighting system shall be provided as per I.S. specification.
9. Arrangement shall have to be made for regular checking, testing and maintenance of all the Fire fighting installation in the building to keep them in perfectly good working condition at all the times.
10. A Fire control room including a closed circuit T.V. system will have to be maintained which observed all floor of the building
11. A crew of trained Fireman under an experienced officer shall be maintained round the clock for safety of the Building.
12. If required the old lines shall have to be replaced with new lines, the cable shall always be laid in M.S. Conduits pipes continuously bonded with earth.
13. The underground water reservoir of at least 10000 ltrs. shall have to be provided and standby fire pump shall have to be installed before renewal of this certificate.
14. Periodical flashing of water from the hydrants and sprinkler pipe line shall be made to maintain efficient working performance of above mentioned system.
15. The Fire safety audit to be conducted a regular interval and to be recorded in the Fire prevention maintenance register.
16. This F.S.C. is valid for 03(three) years and have to be renewed every 03 (three) years from the date of issue of this letter.

Signature valid

Digitally signed by DIPAK
KUMAR GHOSH
Date: 2020.07.13 17:09:02 IST

Divisional Fire Officer, South 24 Parganas
West Bengal Fire & Emergency Services